

TRANSMISSION CORPORATION OF ANDHRA PRADESH LIMITED

From:
Executive Director
Planning, RAC & Reforms
APTRANSCO, Vidyut Soudha,
Khairatabad, Hyderabad - 500082

To,
✓ M/s Nagineni Natural Resources Pvt Ltd,
MIG: B-74, Dr A.S.Rao Nagar,
Hyderabad - 500 062.

Lr.No.ED(Plg,RAC&Ref)/ADE(C)/F. Nagineni-ATP/ DNo. 527/13, Dt:28.08.13

Sir,

Sub: M/s Nagineni Natural Resources Pvt Ltd - Evacuation of 100 MW Solar Photovoltaic Power Project at Komatikuntla (V), Putlur (M), Ananthapur district - Connectivity/Evacuation Approval issued - Reg.

Ref: Your Application Dt: 07.03.2013

* * *

With reference to the letter cited, it is to inform that, APTRANSCO has decided to give connectivity to your plant for evacuating power of 100MW from Solar Power Project at Komatikuntla (V), Putlur (M), Ananthapur district. For evacuation of solar generation, you are requested to lay 30 KM - 220KV DC/SC Line up to proposed 220/132KV Tirumalaipally SS from proposed Solar Power station at Komatikuntla subject to the following conditions.

- I. Cost of laying of 220KV DC/SC line including both side bays is to be borne by the developer as per the regulation in vogue.
- II. Cost of the Land for 220 KV Bay extensions at 220/132KV Tirumalaipally SS is to be procured by the developer at his cost and to be handed over to APTRANSCO.
- III. The Development of Solar Project under Cluster System, the developer has to construct the Pooling Station and the cost is to be borne by the developer and necessary estimate charges to be paid.
- IV. Further, as per the clause No 4.6.2 of Indian Electricity Grid Code 2010, it is mandatory to provide data to SLDC prior to charging of the equipment. As per the clause 5.2(u) of Indian Electricity Grid Code 2010, Data Acquisition System facility shall be provided for transfer of information to concerned SLDC and RLDC for Solar/wind generators. Hence it is requested to provide necessary communication & Data Acquisition System for the above Solar Project.

- V. You are requested to submit the BG/SD of Rs 2.00 Lakhs/MW with in 45 days, with a validity of one Year from the date of issue and encashable period for another 2 Months. This will be refunded if the project is commissioned within one Year. In case the developer is unable to complete the project within one year, the BG/SD shall be forfeited besides encashment of BG.
- VI. To make payment of the Supervision, Engineering and other charges etc with in 15 days from the date of receipt of intimation from APTRANSCO. Failure to do so will lead to cancellation of the connectivity provided and no further correspondence will be entertained in this regard.
- VII. The Developer responsibility to procure the necessary land and financial closure with in six months from the date of issue of connectivity/evacuation approval. Necessary documents has to be provided with in six months from the date of issue of connectivity approval.
- VIII. The project is to be commissioned with in one year from the date of payment of supervision charges. Failure to do so will lead to cancellation of the connectivity provided and no further correspondence will be entertained in this regard.

Further, you are requested to submit your consent to take up the work on turnkey basis duly paying the supervision charges, Engineering Charges, Service tax and cost of spares, etc. to APTRANSCO.

After receipt of the consent letter further necessary action will be taken.

Yours faithfully,

B.V. Shanthi Saha
28/8/13

Executive Director
Planning, RAC & Reforms

Copy to:

Chief Engineer/Power Systems/APTRANSCO/VS/Hyderabad

Chief Engineer/IPC/APPCC/VS/Hyderabad

Chief Engineer/SLDC/APTRANSCO/VS/Hyderabad

Chief Engineer/ Zone/ APTRANSCO/Kadapa

Chief Engineer/Construction-2/APTRANSCO/VS/Hyd- **It is requested to prepare the detailed estimate as early as possible.**